



Finance
 Purchasing Division
 929 N Front St., 10th Floor
 Post Office Box 1810
 Wilmington, NC 28402-1810

910 341-7830
 910 341-7842 fax
 wilmingtonnc.gov
 Dial 711 TTY/Voice

ADDENDUM NUMBER 4
Generator Replacements at WFD Headquarters and Fire Station No. 7
 PB-EDI-0724
 September 11, 2024

To all holders of Bid Documents, please be advised to the following:

	Question	Response
1	I know you has all of this “Engineered” but I was wondering why you are continuing to use a day tank at Fire Headquarters?	The main fuel storage tank is separate from the generator and exterior to the building. A day tank has been indicated in the design to ensure there is adequate fuel supply to the interior generator equipment. EDi would not take exception to a generator / fuel system provided that does not require a day tank; however, the Contractor / Manufacturer would be required to provide documentation to confirm the fuel system is adequate for the generator / exterior fuel tank arrangement as indicated on the Contract Documents and include all necessary accessories / components (e.g., upsized fuel pumps, backflow valves, etc.) to support the fueling configuration noted without the use of a day tank.
2	I was told that Generac was the basis of design for these two gensets, is this correct?	The basis of design for the generator equipment was by Generac.
3		
4		
5		
6		
7.		
8.		
9.		

Acknowledge receipt of this Addendum in the space provided in the Proposal. Failure to do so may disqualify the Bidder.

All other terms and conditions remain unchanged.

Daryle L. Parker, Purchasing Manager
Purchasing Division
END OF ADDENDUM FOUR