



NOTES:

1. CONCRETE SHALL BE CLASS "A" (3000 PSI MIN.).
2. REBAR SHALL HAVE A MIN. COVER OF 3".
3. TOP SHALL BE SET TO BE FLUSH WITH SIDEWALK AND FLUSH WITH CATCH BASIN CASTING.
4. AFTER TOP HAS BEEN PLACED, THE CONTRACTOR SHALL FILL THE LIFTING HOLE WITH LOW STRENGTH GROUT.

PIPE SIZE	B	C
30" , 36"	3'-4 1/2"	2'-11 3/4"
42"	3'-10 1/2"	3'-5 3/4"

STANDARD DETAIL

SLAB TOP FOR
MODIFIED CATCH BASIN



CITY OF WILMINGTON ENGINEERING
PO BOX 1810
WILMINGTON, NC 28402
(910) 341-7807

SD 2-11

DATE: 2001

DRAWN BY JSR/CMR

CHECKED BY B.P., P.E.

SCALE NOT TO SCALE